



# HENDERSON COUNTY PUBLIC SCHOOLS

414 Fourth Avenue West, Hendersonville, NC 28739-4261  
Mark R. Garrett, Superintendent

Board of Public Education  
Dr. Kathy Revis, Chairperson  
Robert Bridges, Vice Chairperson  
Beth Campbell  
Blair Craven  
Shelia Dale  
Amy Lynn Holt  
Alyssa Norman

## ADDENDUM 02

### EHHS STADIUM VISITOR GRANDSTAND REPLACEMENT HENDERSON COUNTY PUBLIC SCHOOLS

MLA PROJECT NUMBER: 25002

HCPS IFB NUMBER: 2025-10

Mark Lusk Architecture, PLLC  
128 Woodburn Drive  
Swannanoa, NC 28778

**DATE OF ISSUE: April 3, 2025**

#### **TO: ALL BIDDERS OF RECORD**

This Addendum modifies the Contract Documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become a part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

#### **BIDDERS SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM ON BID FORM.**

This Addendum consists of one page(s) and any enclosures noted:

#### **I. ENCLOSURES:**

1. C101

#### **II. GENERAL INFORMATION / CLARIFICATIONS**

1. Per specifications, the grandstand design is I Beam construction. Angle frame grandstand design is not permitted.
2. Per specifications, the grandstand concrete pier foundations and support slab for the elevated walkway are engineered by the grandstand supplier and it is anticipated (not required) the GC will coordinate with the supplier to provide the pier foundations. The intent is for the GC to have the site work complete and ready for the construction of the grandstand structure to proceed upon delivery to the site.
3. The bid envelopes as noted in the Invitation For Bids shall be as follows:
  - A. The sealed outside envelope shall contain the bid bond, if required, along with the sealed inside envelope.
  - B. The sealed inside envelope shall contain the bid and related documents.

#### **III. CHANGES TO PROJECT MANUAL:**

1. None

#### **IV. CHANGES TO DRAWINGS:**

1. Refer to C101: Provide additional concrete walk for accessible pathway.

#### **END OF ADDENDUM**