

ADDENDUM 01

RFP 2026-15 Rugby Middle School Sidewalk Project

VENDOR QUESTIONS:

1. Do we need to confirm compacted stone depth below existing sidewalk and add to a certain depth if it is insufficient or are we to assume that the existing base is sufficient and we will not add to it? **ANSWER: *We are going to assume the existing base is sufficient.***
2. Do you want steel mesh reinforcement or fiber concrete? **ANSWER: *We want concrete fiber.***
3. Does alternate 3 include the bus ramp sidewalks? **ANSWER: *Alternate 3 starts at the first white mark under the bus awning on the left-hand portion of the building as facing from the parking lot and runs all the way across the front. Alternate 2 concrete should be included in Alternate 3 as well for a total price of all sidewalk portions connected to the building.***