

Addendum #1 for RFQ 2026-12

Water Service Plans for East Henderson High School
Issued: June 1, 2026

This Addendum shall be attached to and made a part of the above named Contract Documents.

The following items are issued to, modify, and clarify the Contract Documents. These items shall have full force and effect as the Contract Documents, and cost involved shall be included in the Bid prices. Bids, to be submitted on the specified date, shall conform to the additions and revisions listed herein.

Acknowledge receipt of the Addendum on the Bid. Failure to do so may subject the bidder to disqualification.

ADDENDUM ITEMS

1. The mandatory pre-bid meeting was held on-site on Wednesday May 27th. The attached bidders list is included in the addendum.
2. HCPS will run the power to the new hot box. The awarded bidder will be responsible for providing the heater inside the enclosure.
3. The awarded contractor shall provide material submittals for review prior to installation.
4. The proposed RPZ (Watts 774 OSY) has been purchased by the owner. The full specifications of the purchased assembly is included in the addendum. The model referenced on Sheet C-500 (note 12) is incorrect.
5. A bypass line is not desired. A bypass line could inadvertently provide unprotected water to the system.
6. The backflow preventer assembly should be tested by a certified backflow tester prior to turning over the assembly to the owner. A list of City of Hendersonville approved/certified testers is online at the backflow prevention website.
7. As shown on Sht. C-500, the existing water main is 4"-DIP. As shown on Sht. C-500, the proposed water main is 4"-DIP/CL-350.
8. East Henderson High School is not sprinkled. An FDC Connection **will not be** required on the backflow device.

END OF ADDENDUM #1

MANDATORY PRE -BID CONFERENCE & SITE VISIT SIGN IN RFQ 2026-







12

HENDERSON COUNTY PUBLIC SCHOOLS

EHHS WATER SERVICES

MAY 27, 2026

10:00 am (EST)

COMPANY (name/address)	REPRESENTATIVE NAME	Email	Mobile Phone	MUST SIGN HERE
NRH Engineering SVS	Jessica W	hrhengineeringServices@gmail	864 497 5891	
Carolina Specialties Construction	Christian Carswell	ccarswell@cscwnc.com	828-435-1122	Christian C.
Austin Construction	Brian Austin	Brian.Gaustine.net	828-779-9887	
Dan Grady	Mike Lounged	Mlovingood@dayjcdp.com	828 507-8649	
Gosnell Construction Utility	Mark Gosnell	ladgos@bellsouth.net	828-674-9052	Mark Gosnell
Chanzic Inc	Brandon Niebur	Brandon@Chanzic.com	321-914-2647	
Patterson Const. Cotlar STEVENS		Cotlar Patterson Const. Group, Inc	828-687-0269	Cotlar Steve
BOLTON	Steve Warrillow	Steve.Warrillow@webolton.com	828-493-8225	
Bolton	Mike Levins	mikelevins@webolton.com	828 772 5063	

CHAD DILLON, Director of Facilities : _____ Date: _____

Job Name _____

Contractor _____

Job Location _____

Approval _____

Engineer _____

Contractor's P.O. No. _____

Approval _____

Representative _____

LEAD FREE*

Series 774

Double Check Valve Assemblies

Sizes: 2½" – 12"


Series 774 Double Check Valve Assemblies are designed to prevent the reverse flow of polluted water from entering into the potable water system. This series can be applied, where approved by the local authority having jurisdiction, on non-health hazard installations. Features short end-to-end dimensions, light weight stainless steel body, and the lowest head loss available.

Features

- Torsion spring check valve provides low head loss
- Short lay length is ideally suited for retrofit installations
- Stainless steel body is half the weight of competitive designs reducing installation and shipping cost
- Stainless steel construction provides long term corrosion protection and maximum strength
- Single top access cover with two-bolt grooved style coupling for ease of maintenance
- Thermoplastic and stainless steel check valves for trouble-free operation
- No special tools required for servicing
- Compact construction allows for smaller vaults and enclosures
- May be installed in horizontal or vertical "flow up" position

Specifications

A Double Check Valve Assembly shall be installed at each noted location to prevent the unwanted reversal of polluted water into the potable water supply. The main valve body shall be manufactured from 300 series stainless steel to provide corrosion resistance. The check valves shall be of thermoplastic construction with stainless steel hinge pins, cam arm, and cam bearing. The check valves shall utilize a single torsion spring design to minimize pressure drop through the assembly. The check valves shall be modular and shall seal to the main valve body by the use of an O-ring. There shall be no brass or bronze parts used within the check valve assembly. The valve cover shall be held in place through the use of a single grooved style two-bolt coupling. The main assembly shall consist of two independently operating torsion spring check assemblies, two resilient seated isolation valves, and four ball valve type test cocks. The assembly shall be a Watts Series 774.



Now Available WattsBox Insulated Enclosures.

For more information, send for literature ES-WB.

NOTICE

The information contained herein is not intended to replace the full product installation and safety information available or the experience of a trained product installer. You are required to thoroughly read all installation instructions and product safety information before beginning the installation of this product.

NOTICE

Inquire with governing authorities for local installation requirements


*The wetted surface of this product contacted by consumable water contains less than 0.25% of lead by weight.

Available Models

Suffix:

- NRS** Non-rising stem resilient seated gate valves
- OSY** UL/FM resilient seated outside stem & yoke gate valves
- LF** Without shutoff valves
- S** Cast iron strainer
- **OSY FxG** Flanged inlet gate connection and grooved outlet gate connection
- **OSY GxF** Grooved inlet gate connection and flanged outlet gate connection
- **OSY GxG** Grooved inlet gate connection and grooved outlet gate connection

Available with grooved NRS gate valves - consult factory**
 Post indicator plate and operating nut available - consult factory**
 **Consult factory for dimensions



Materials

- All internal metal parts: 300 Series stainless steel
- Main valve body: 300 Series stainless steel
- Check assembly: Noryl®
- Flange dimension in accordance with AWWA Class D


Pressure - Temperature

- Temperature Range: 33°F – 110°F (0.5°C – 43°C) continuous
- Maximum Working Pressure: 175psi (12.1 bar)

Standards


AWWA C510-92, CSA B64.5

Approvals



For 12" assembly approvals consult factory.

Dimensions - Weight










SIZE	DIMENSIONS												WEIGHT									
	A		C (open)				D		G		L		M		N		S		w/Gates		w/o Gates	
	in.	mm	OSY		NRS		in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs.	kgs.	lbs.	kgs.
2½	37	940	16¾	416	9¾	238	3½	89	10	254	22	559	10	254	6½	165	7	178	140	64	53	24
3	38	965	18⅞	479	10¼	260	3¾	95	15	381	22	559	10⅞	257	7	178	7½	191	215	98	55	25
4	40	1016	22¾	578	12⅝	310	4½	114	10	254	22	559	12⅞	308	8¼	210	9	229	225	102	58	26
6	48½	1232	30⅞	765	16	406	5½	140	15	381	27½	699	18½	470	13½	343	11	279	375	170	105	48
8	52½	1334	37¾	959	19⅝	506	6¾	171	15	381	29½	749	21⅝	549	15½	394	13½	343	561	254	169	77
10	55½	1410	45¾	1162	23⅝	605	8	200	15	381	29½	749	26	660	18½	470	16	406	763	346	179	81
12	57½	1461	53⅞	1349	26¾	679	9½	241	15	381	29½	749	29⅞	759	21¾	552	19	483	1033	469	209	95

Noryl® is a registered trademark of General Electric Company

Capacity

Rate of working pressure 175psi (12.1 bar) * Rate of flow, ** UL Tested



USA: T: (978) 689-6066 • F: (978) 975-8350 • Watts.com
 Canada: T: (888) 208-8927 • F: (888) 479-2887 • Watts.ca
 Latin America: T: (52) 55-4122-0138 • Watts.com