



**Henderson County Public Schools**  
414 Fourth Avenue West  
Hendersonville, North Carolina 28739

## **Addendum #2**

### ***Water Service Plans for East Henderson High School*** **June 3, 2026**

This Addendum shall be attached to and made a part of the above named Contract Documents.

The following items are issued to, modify, and clarify the Contract Documents. These items shall have full force and effect as the Contract Documents, and cost involved shall be included in the Bid prices. Bids, to be submitted on the specified date, shall conform to the additions and revisions listed herein.

Acknowledge receipt of the Addendum on the Bid. Failure to do so may subject the bidder to disqualification.

#### **ADDENDUM ITEMS**

1. As indicated on the RFQ – all bids must be hard-copies, and sealed. Proposals submitted via E-Mail or Fax machine will not be accepted.
2. The contractor shall provide the hotbox enclosure. As indicated on C-500, note 13, the hot-box enclosure shall be fiberglass (BFP Products or approved equal).
3. The Watts 774-OSY 4” Double Check valve assembly backflow preventer has been approved for use by the City of Hendersonville. The approval for this is included for reference herein.

**END OF ADDENDUM #2**



THE BACKFLOW PREVENTION  
ASSEMBLY APPLICATION HAS BEEN  
APPROVED FOR

*East Henderson High School*

150 Eagle Pride Drive  
East Flat Rock, NC, 28726

*Gracie Erwin 03/05/2026*

---

**GRACIE ERWIN**  
Utilities Compliance  
Coordinator

**Watts 774**  
**4" DC Domestic**

---

**BFP MAKE, MODEL  
SIZE, TYPE, AND SERVICE**